

N.C. DEPARTMENT OF HEALTH, ENVIRONMENT AND NATURAL RESOURCES
Ground Water Section

UST '24-HOUR NOTICE' INFORMATION SHEET

Date: 12 / 30 / 92 Time: 10:00 Tech: Knight

Name: Chris Boggs - ENSCI

Phone #: (919) 883-7505

Tank Owner: Lyles Chevrolet "TRANSCO PROPERTY"

Address: 1730 N. Main Street

High Point NC 272

Location: Same

Directions:

Nature of Release:

Product: gasoline Size of Tank: 1000 gallon

Amount Lost: unknown Age of Tank: late 60's

Free Product: Yes ☒ (No)

How was release discovered?: tank pull last week

thought it had already been reported

Release reported within 24 hours: Yes ☒ (No)

Tank removal to take place (if applicable): / /

Comments: 3 tanks pulled

7,500^{gas} / 1000^{#2} / 1000^{gas} - 1000 gal gas tank had large hole

Excavated below 100 ppm PID

Stockpiled soil / backfilled hole

Tank out of service >10 years